

Site 2 Sand and Salt Storage Hoop Building
Cedar Rapids Linn County Solid Waste Agency
Cedar Rapids, Iowa

Cedar Rapids Linn County Solid Waste Agency
1954 County Home Road
Marion, Iowa 52403

To: Bidding Document Holders of Record

The information contained in this Addendum modifies, supplements, or replaces information contained in the Request for Bids and is hereby made a part of the Contract Documents.

This addendum contains 1 page of text.

REQUEST FOR BIDS ITEMS

Figure 1

Revise Note 1.1 to read as follows:

The building's width shall be between 24' wide to 32' wide and be open on the south facing side.

Add Note 6.6 to read as follows:

The building's fabric cover shall be a flame-retardant material that meets NFPA requirements as outlined in the International Building Code.

ADDITIONAL CLARIFICATIONS & INFORMATION

Question: Will the vendor be required to provide stamped / sealed drawings for the foundation design, or just assist with the layout?

Answer: The bid should assume that a sealed foundation design will not be required by the permitting authority.

Question: Will there be a cost to the awarded contractor for the permitting on the building?

Answer: The bid should account for the vendor's time to assist with completing the required permit applications. The Agency will pay the cost of the required permit fees directly to the permitting authority.

Question: I see the design wind speed is called out as 115mph V Ult, which requires the building to be engineered as a risk category II. Please confirm if this is required or if a risk category I would be acceptable as an unoccupied structure.

Answer: The provided bid should be for a structure that meets the design criteria outlined in the Request for Bids.

End of Addendum No. 1